

BASE4

BASE4
3858 GLADES ROAD, #31
BOCA RATON, FLORIDA 33434
1.720.725.4544 www.base-4.com

SEAL



GARRY VERMAAS, PhD, PE
2016.08.05
9011 EDGEWATER BEND
PARKLAND, FLORIDA, 33076



ISSUE:

Issued for Permit
08.05.2016

PROJECT: 16-018

Hampton Inn & Suites

New Stanton, PA 15672

OWNER:

Stanton Hospitality LLC

52 Blueberry Lane,
Grove City, PA 16127

No.	Issue Date	Project Status

DATE2016.08.05

DRAWN BYSJ

CHECKED BYGWV

SCALEAS NOTED

PROJECT NO.B4-67-1603





SHEET NAME

LIGHTING FIXTURE
SCHEDULE

SHEET NO.

E002



LIGHTING FIXTURE SCHEDULE

LEGEND	TYPE	WATTS	MNTG	FINISH	LAMP TYPE	VOLTAGE	DESCRIPTION	LOCATION
	D-1A	30 WATTS.	RECESSED	WHITE TRIM	LED	120	6" LED RECESSED DOWNLIGHT, 1,700 DELIVERED LUMENS, 2700K, 90 + CRI	POOL, CORRIDOR, BUISNESS CENTER, ELEVATOR LOBBY, TREATS SHOP, MENS RESTROOM, WOMENS RESTROOM, PANTRY, MIAN LAUNDRY, FRONT DESK, VENDING
	D-2A	30 WATTS.	RECESSED	BRUSHED NICKEL	LED	120	6" LED RECESSED WALL WASH, 1,700 DELIVERED LUMENS, 90 + CRI	FRONT DESK, BREAKFAST AREA, VESTIBULE
	D	-----	ARCHITECT TO CONFIRM	-----	LED	120	ARCHITECT TO CONFIRM	VESITBULE, MEETING ROOM, PORTE COCHERE
	W1-A	44 WATTS.	SURFACE	WHITE TRIM	LED	120	4' LED STRIP, 2500 LUMENS, 3500K, 90 + CRI	ELECTRICAL ROOM, STORAGE, WATER HEATER, MECHANICAL ROOM, PBX ROOM,
	W2-A	44 WATTS.	WALL	WHITE TRIM	LED	120	4' LED STAIRWELL FIXTURE WITH OCCUPANCY SENSORS	STAIR LIGHTS
	T2-A	35 WATTS.	LAY-IN	WHITE TRIM	LED	120	2' x 2' LED TROFFER, 3200 LUMENS, 3500K, 90 + CRI, 0-10V DIMMING	POOL, CORRIDOR, BUISNESS CENTER, ELEVATOR LOBBY, TREATS SHOP, MENS RESTROOM, WOMENS RESTROOM, PANTRY, MIAN LAUNDRY, FRONT DESK, VENDING
	T3-A	44 WATTS.	LAY-IN	WHITE TRIM	LED	120	2' X 4' LED TROFFER, 4000 LUMENS, 3500K, 90+ CRI, 0-10V DIMMING	POOL, CORRIDOR, BUISNESS CENTER, ELEVATOR LOBBY, TREATS SHOP, MENS RESTROOM, WOMENS RESTROOM, PANTRY, MIAN LAUNDRY, FRONT DESK, VENDING
	EX	05 WATTS.	SURFACE	WHITE TRIM	LED	120	LED EXIT SIGN	EMERGENCY EXIT LIGHTS
	P1	35 WATTS.	PENDANT	BRUSHED ALUMINUM			20" DIAMETER LED DECORATIVE PENDANT, 1000+ LUMENS, 3000K, 90+ CRI	BREAKFAST AREA
	P2	12 WATTS.	PENDANT	SATIN NICKEL	LED	120	16" LENGTH LED DECORATIVE PENDANT, 1363 DELIVERED LUMENS, 90+ CRI	PANTRY

GUEST ROOM LIGHTING FIXTURE SCHEDULE





	N	32 WATTS.	WALL	WHITE TRIM	LED	120	6" LED DOWNLIGHT, 800 DELIVERED LUMENS, 2700K, 90+ CRI	GUESTROOM / GUEST BATH
	A	32 WATTS.	VANITY LIGHT	BRUSHED NICKEL	LED	120	36" LED VANITY 2300 DELIVERED LUMENS, 2700K, 90+ CRI	GUEST BATH

EXTERIOR LIGHTING FIXTURE SCHEDULE

	SC-1	10.5 WATTS.	SURFACE WALL	BRUSHED NICKEL	LED	120	15" WIDE LED SCONCE FABRIC SHADE 250 LUMENS, 2700K, 90+ CRI	EXTERIOR DOOR LIGHTS
	FF	32 WATTS.	SURFACE WALL	BRUSHED NICKEL	LED	120	120 VOLT FINISH SELECTED BY ARCHITECT. REFERS TO ARCHITECTS ELEVATION FOR MOUNTING HEIGHTS.	PORTE COCHERE

SITE LIGHTING FIXTURE SCHEDULE

Luminaire Schedule

Symbol	Qty	Label	Lum. Lumens	Lum. Watts	LLF	Description	Filename	Arrangement
	09	H	3141	44.19	0.900	KR6-40L-27K-xxxV-xxx RECESSED	KR6-40L with KR6T-SSGC.ies	SINGLE
	10	A1	30657	426	0.900	ARE-EHO-4M-xx-12-E-UL-xx-1000-40K (1000mA)	ARE-EHO-4M-__-12-E-UL-1000-40K.ies	SINGLE
	04	A1 BTB	30657	426	0.900	ARE-EHO-4M-xx-12-E-UL-xx-1000-40K (1000mA)	ARE-EHO-4M-__-12-E-UL-1000-40K.ies	BACK - BACK
	25	BO	1813	34	0.900	PWY-EDG-2M-02-E-UL-525-40K	PWY-EDG-2M-xx-02-E-UL-525-40K_PL05758-001A.ies	SINGLE

NOTE:

- PROVIDE LIGHT FIXTURE AS SPECIFIED IN LIGHTING SCHEDULE AND ACCOMPANYING CONTROLS PACKAGE INCLUDING OCCUPANCY SENSOR, DAYLIGHT SENSORS, DIMMING SWITCHES AND WIRELESS CONTROL AS SPECIFIED BY LIGHTING PACKAGE.
- ALL EXTERIOR FIXTURES TO BE SELECTED BY ARCHITECT/ OWNER.
- FOR LIGHTING PACKAGE BID, ELECTRICAL CONTRACTOR SHALL CONTACT ANTHONY CANON AT GENPRO LIGHITNG SOLUTIONS, LLC: anthony@genproenergy.com or 727-599-5617